

Our ref: GTL-2019-012-2

Date: 1 November 2021

Dear Valued Customers,

Re : Verification of Hey Hey Fan Model HH-101 and Model HH102 are in compliance with Building Energy Efficiency Ordinance (Cap. 610)

This is to confirm that Hey Hey Fan Model HH-101 and Model HH102 are in compliance with Building Energy Efficiency Ordinance (Cap. 610).

The system fan motor of Model HH-101/ Model HH102 does not exceed 1.1W per L/s of exhaust air flow or fresh air flow rate whichever the larger (BEC Clause 6.7.6)

Yours faithfully,

For and on behalf of

Hey Hey Technology Limited

126 

Ir Ng Tat Ho Derek

Registered Energy Assessor

Reg. no.: EA00096G